

Annexure-11

Government of Tripura
Directorate of Fire Service
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No.3-8/TFS/2020/ 6213-15

Dated, Agartala, the 07 July, 2020

To
The Principal,
Holy Cross College,
Jubatara, Lembucherra, West Tripura.
Mobile No. 9402315672.

Subject: - Issuance of No Objection Certificate.

With reference to your Compliance report/Application under No. nil dated 22.05.2020, it hereby certified that the building /premises as per description below has been inspected by the officer concerned of this department in respect of implementation of fire safety measures and it was found that said building have complied with the Fire Prevention and Fire Safety requirements accordance with provisions of the Part-IV of the latest National Building Code in force in Tripura. The premises/building is declared fit for occupancy with effect from 07/07/2020 for a period of 1(One) year subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building / premises: - The Principal, Holy Cross College, Jubatara, Lembucherra, West Tripura.

Issued on _____ at Agartala.


Joint Director
Tripura Fire Service

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction or occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction or projection.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills conducted at regular intervals and record be maintained.

Copy to :-

- a. The Divisional Fire Officer, West Division, Agartala for information.
- b. OC, Agartala Fire Station for favour of Information.